

Fax to

Company : Phoenixtec Power Co., Ltd.
Attention : Mr. Wilson Kuo
Telephone : 02-66006688 Ext. 2526
Fax : 02-66068704
E-mail : wilsonkuo@phoenixtec.com.tw
Your Ref. : 8994800032/JL170511
8994800052/JL300611

From

Company : TÜV Rheinland Taiwan Ltd.
Name : Mr. Best Chen
Telephone : 2172-7000 Ext. 1183
Fax : 2528-0018
E-mail : bcc@tw.n.tuv.com
Our Ref. : BCC/EVC-113148391/113148393

Date: 9 July, 2012

Number of Pages (in total) : 1

Subject : Notification of Test Result

Dear Mr. Kuo,

We herewith notify that the product : PV Inverter

Type designation : SV10000s, SV 15000s, SV 20000s (Phoenixtec Power)

has been type -tested and found in compliance with

Test Requirement : DIN V VDE V 0126-1-1 : 2006 &
DIN V VDE V 0126-1-1 : 2006/A1

This letter is not a substitute for a certificate.

The test report and all required documents are under preparation.

When contacting our office, please refer to our reference number listed above.

Please contact our office for approval of your new products.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Yours sincerely

TÜV RHEINLAND TAIWAN LTD.
Power Supply Product Line



David Lee
General Manager



Best Chen
Senior Manager

TÜV Rheinland Taiwan Ltd.

Page 1 of 1