



4.5.	附表：正常頻率操作範圍 - GW6000-DNS-30 (220 V)			符合
	設定值	實測值(L1/L2/L3)		單位
正常頻率	60.0	—	—	(Hz)
正常頻率+ 1 Hz	61.0	—	—	(Hz)
正常頻率 -1 Hz	59.0	—	—	(Hz)
正常頻率 -2 Hz	58.0	—	—	(Hz)

備註：
 1. PV 系統頻率應與市電系統同步，在本標準第 5.2.2 節所定義之頻率失誤限制之內，其測試結果如附表 5.2.2。
 2. 正常頻率-2 Hz 係為台電需求規範要求加測項目。

4.6.	附表：諧波及波形失真 - GW6000-DNS-30 (220 V)				—
相序	L1	L2	L3	限制值(%)	
THD	1.001	—	—	5.0	
2	0.066	—	—	1.0	
3	0.110	—	—	4.0	
4	0.018	—	—	1.0	
5	0.018	—	—	4.0	
6	0.009	—	—	1.0	
7	0.085	—	—	4.0	
8	0.013	—	—	1.0	
9	0.164	—	—	4.0	
10	0.011	—	—	1.0	
11	0.437	—	—	2.0	
12	0.011	—	—	0.5	
13	0.405	—	—	2.0	
14	0.010	—	—	0.5	
15	0.376	—	—	2.0	
16	0.009	—	—	0.5	
17	0.326	—	—	1.5	
18	0.010	—	—	0.375	
19	0.288	—	—	1.5	
20	0.008	—	—	0.375	
21	0.258	—	—	1.5	
22	0.010	—	—	0.375	
23	0.232	—	—	0.6	
24	0.010	—	—	0.15	
25	0.196	—	—	0.6	
26	0.008	—	—	0.15	
27	0.172	—	—	0.6	
28	0.007	—	—	0.15	
29	0.148	—	—	0.6	
30	0.008	—	—	0.15	
31	0.130	—	—	0.6	
32	0.007	—	—	0.15	
33	0.108	—	—	0.6	
34	0.006	—	—	0.15	
35	0.098	—	—	0.3	



財團法人

台灣大電力研究試驗中心

Taiwan Electric Research & Testing Center

再生能源實驗室

報告編號：DRT20230008

36	0.005	—	—	0.075
37	0.087	—	—	0.3
38	0.005	—	—	0.075
39	0.072	—	—	0.3
40	0.004	—	—	0.075

4.6. 附表：諧波及波形失真 – GW5000-DNS-30 (220 V)				
相序	L1	L2	L3	—
THD	1.222	—	—	限制值(%)
2	0.086	—	—	5.0
3	0.118	—	—	1.0
4	0.021	—	—	4.0
5	0.036	—	—	1.0
6	0.012	—	—	4.0
7	0.114	—	—	1.0
8	0.014	—	—	4.0
9	0.210	—	—	1.0
10	0.012	—	—	4.0
11	0.609	—	—	1.0
12	0.013	—	—	2.0
13	0.535	—	—	0.5
14	0.011	—	—	2.0
15	0.446	—	—	0.5
16	0.011	—	—	2.0
17	0.376	—	—	0.5
18	0.010	—	—	1.5
19	0.334	—	—	0.375
20	0.010	—	—	1.5
21	0.284	—	—	0.375
22	0.009	—	—	1.5
23	0.244	—	—	0.375
24	0.008	—	—	0.6
25	0.212	—	—	0.15
26	0.007	—	—	0.6
27	0.180	—	—	0.15
28	0.007	—	—	0.6
29	0.156	—	—	0.15
30	0.007	—	—	0.6
31	0.138	—	—	0.15
32	0.007	—	—	0.6
33	0.116	—	—	0.15
34	0.006	—	—	0.6
35	0.105	—	—	0.15
36	0.005	—	—	0.3
37	0.093	—	—	0.075
38	0.005	—	—	0.3
39	0.080	—	—	0.075
40	0.005	—	—	0.3