



財團法人

台灣大電力研究試驗中心

Taiwan Electric Research & Testing Center

再生能源實驗室

報告編號：DRT20210018

4.4. 附表：直流注入- GW25KS-MT				符 合
額定最大輸出電流(A)	直流注入實測值(mA)			限制值 (mA)
40	L1	L2	L3	200.0
	57.21	87.41	77.33	

4.5. 附表：正常頻率操作範圍-				符 合
設定值	實測值(L1/L2/L3)			單位
正常頻率	60.0	60.0	60.0	(Hz)
正常頻率 + 1 Hz	61.0	61.0	61.0	(Hz)
正常頻率 - 1 Hz	59.0	59.0	59.0	(Hz)
正常頻率 - 2 Hz	58.0	58.0	58.0	(Hz)

備註：

- PV 系統頻率應與市電系統同步，在本標準第 5.2.2 節所定義之頻率失誤限制之內，其測試結果如附表 5.2.2。
- 正常頻率-2 Hz 為台電需求規範要求加測項目。

4.6. 附表：諧波及波形失真-主型 GW36KS-MT				—
相序	L1	L2	L3	限制值(%)
THD	1.038	1.307	1.223	5.0
2	0.775	0.637	0.828	1.0
3	0.267	0.372	0.463	4.0
4	0.126	0.141	0.230	1.0
5	0.171	0.447	0.359	4.0
6	0.075	0.067	0.139	1.0
7	0.284	0.152	0.323	4.0
8	0.038	0.085	0.092	1.0
9	0.127	0.061	0.176	4.0
10	0.100	0.094	0.105	1.0
11	0.034	0.086	0.084	2.0
12	0.016	0.024	0.033	0.5
13	0.098	0.062	0.051	2.0
14	0.069	0.082	0.089	0.5
15	0.044	0.039	0.080	2.0
16	0.064	0.061	0.064	0.5
17	0.120	0.145	0.078	1.5
18	0.015	0.022	0.022	0.375
19	0.145	0.111	0.095	1.5
20	0.081	0.067	0.074	0.375
21	0.031	0.045	0.077	1.5
22	0.099	0.107	0.092	0.375
23	0.120	0.163	0.088	0.6
24	0.019	0.022	0.031	0.15
25	0.157	0.122	0.149	0.6
26	0.106	0.074	0.076	0.15
27	0.048	0.042	0.081	0.6



財團法人

台灣大電力研究試驗中心

Taiwan Electric Research & Testing Center

再生能源實驗室

報告編號：DRT20210018

28	0.097	0.110	0.082	0.15
29	0.059	0.154	0.145	0.6
30	0.039	0.026	0.049	0.15
31	0.188	0.146	0.156	0.6
32	0.100	0.088	0.037	0.15
33	0.042	0.022	0.048	0.6
34	0.076	0.102	0.059	0.15
35	0.078	0.141	0.106	0.3
36	0.038	0.018	0.051	0.075
37	0.117	0.101	0.133	0.3
38	0.067	0.059	0.039	0.075
39	0.069	0.017	0.057	0.3
40	0.051	0.063	0.023	0.075

4.6. 附表：諧波及波形失真-GW30KS-MT				—
相序	L1	L2	L3	限制值(%)
THD	0.831	0.992	0.956	5.0
2	0.648	0.843	0.711	1.0
3	0.230	0.241	0.344	4.0
4	0.099	0.102	0.165	1.0
5	0.097	0.222	0.165	4.0
6	0.086	0.051	0.131	1.0
7	0.137	0.035	0.157	4.0
8	0.020	0.061	0.068	1.0
9	0.147	0.037	0.176	4.0
10	0.050	0.044	0.068	1.0
11	0.043	0.061	0.076	2.0
12	0.024	0.024	0.041	0.5
13	0.068	0.056	0.044	2.0
14	0.024	0.044	0.057	0.5
15	0.047	0.030	0.073	2.0
16	0.027	0.039	0.042	0.5
17	0.106	0.108	0.046	1.5
18	0.025	0.023	0.036	0.375
19	0.110	0.065	0.065	1.5
20	0.043	0.042	0.061	0.375
21	0.052	0.038	0.081	1.5
22	0.049	0.068	0.064	0.375
23	0.082	0.085	0.034	0.6
24	0.016	0.020	0.027	0.15
25	0.114	0.075	0.086	0.6
26	0.064	0.049	0.071	0.15
27	0.021	0.031	0.053	0.6
28	0.054	0.070	0.055	0.15
29	0.092	0.136	0.107	0.6
30	0.021	0.020	0.032	0.15
31	0.111	0.080	0.095	0.6
32	0.065	0.045	0.044	0.15
33	0.020	0.023	0.040	0.6
34	0.058	0.078	0.054	0.15
35	0.051	0.090	0.073	0.3
36	0.019	0.018	0.035	0.075



財團法人

台灣大電力研究試驗中心

Taiwan Electric Research & Testing Center

再生能源實驗室

報告編號：DRT20210018

37	0.152	0.132	0.160	0.3
38	0.066	0.049	0.035	0.075
39	0.039	0.023	0.045	0.3
40	0.059	0.057	0.053	0.075

4.6. 附表：諧波及波形失真-GW25KS-MT				—
相序	L1	L2	L3	限制值(%)
THD	0.963	1.145	1.096	5.0
2	0.768	0.973	0.854	1.0
3	0.243	0.269	0.365	4.0
4	0.109	0.113	0.175	1.0
5	0.121	0.257	0.173	4.0
6	0.089	0.050	0.127	1.0
7	0.138	0.069	0.171	4.0
8	0.020	0.071	0.077	1.0
9	0.167	0.043	0.197	4.0
10	0.060	0.058	0.076	1.0
11	0.050	0.078	0.089	2.0
12	0.029	0.022	0.042	0.5
13	0.095	0.056	0.057	2.0
14	0.034	0.049	0.063	0.5
15	0.059	0.034	0.091	2.0
16	0.042	0.055	0.048	0.5
17	0.105	0.113	0.038	1.5
18	0.027	0.021	0.033	0.375
19	0.094	0.063	0.043	1.5
20	0.073	0.065	0.085	0.375
21	0.057	0.050	0.098	1.5
22	0.076	0.104	0.075	0.375
23	0.087	0.105	0.043	0.6
24	0.022	0.021	0.031	0.15
25	0.137	0.083	0.103	0.6
26	0.100	0.073	0.080	0.15
27	0.027	0.038	0.070	0.6
28	0.084	0.104	0.066	0.15
29	0.080	0.140	0.107	0.6
30	0.030	0.035	0.054	0.15
31	0.096	0.054	0.080	0.6
32	0.093	0.074	0.053	0.15
33	0.027	0.030	0.054	0.6
34	0.089	0.114	0.064	0.15
35	0.035	0.083	0.063	0.3
36	0.030	0.032	0.061	0.075
37	0.154	0.122	0.156	0.3
38	0.097	0.081	0.035	0.075
39	0.053	0.023	0.058	0.3
40	0.074	0.063	0.046	0.075